



GOVERNMENT OF THE DISTRICT OF COLUMBIA
CONSTRUCTION CODES COORDINATING BOARD
c/o DCRA – 1100 4th Street, SW, Washington, DC 20024

CODE CHANGE PROPOSAL FORM

PAGE 1 OF 2

CODE: Fire SECTION NO: 1024 SUBCOMMITTEE AMENDMENT NO. FC-FLS-10-1-13
PROPOSING SUBCOMMITTEE: Fire Life Safety CHAIR: Taylor PHONE: 202 727 1805 E-mail: herbert.taylor@dc.gov
DATES OF PROPOSAL: 4-18-2012 CCCB PRESENTATION: 4-19-2012 CCCB APPROVAL: 4.27

CHECK ONE Revise section to read as follows: Delete section and substitute the following:
 Add new section to read as follows: Delete section without substitution.

TYPE ALL TEXT IN 12-POINT TIMES NEW ROMAN FONT

~~LINE THROUGH TEXT TO BE DELETED~~ (highlight text, under Format, click font and check strikethrough)

UNDERLINE TEXT TO BE ADDED

Use additional sheets of the form, if necessary.

See next page.

Anticipated impact of code change on cost of construction (CHECK ONE)

Increase Decrease Negligible Unknown

Per 1,000 SF single-family dwelling to
Per 1,000SF of commercial building to

JUSTIFICATION OF CHANGE:

Please reference one or more of the criteria required

- To address a critical life/safety, health, general welfare need.
- To address a specific District of Columbia policy or statute
- For consistency with federal, or with reference to the Metro DC area (MD, VA) codes
- Address a unique character issue in the District of Columbia
- Correction of errors and omissions
- Other (explain)

IBC was driven by response to NIST post-9/11 study. DC does not have super-high-rise buildings; DC's height act effectively restricts DC buildings to 13 stories. Durability of the required marking and their continued maintenance is also a concern. This code change was labeled FLS-10-7-11 when approved as a part of 2011 12 DCMR H, on 11-18-2010.



1024 LUMINOUS EGRESS PATH MARKINGS

Strike Section 1024 of the International Fire Code without replacement.