



GOVERNMENT OF THE DISTRICT OF COLUMBIA
CONSTRUCTION CODES COORDINATING BOARD
c/o DCRA- 1100 4th Street SW, Washington, DC 20024

CODE CHANGE PROPOSAL FORM

PAGE 1 OF 2

CODE: Plumbing Code SECTION NO. 1302.4 SUBCOMMITTEE AMENDMENT NO. PC-M-13-5-13

PROPOSING SUBCOMMITTEE: Mechanical TAG CHAIR: Lourenco PHONE: 202-966-0042 E-mail: al@lourenconsult.com

DATES OF PROPOSAL: 6/19/12 CCCB PRESENTATION: 6.28.12 CCCB APPROVAL: 7.3.12

CHECK ONE *Revise section to read as follows:* *Delete section and substitute the following:*
 Add new section to read as follows: *Delete section without substitution.*

TYPE ALL TEXT IN 12-POINT TIMES NEW ROMAN FONT
~~LINE THROUGH TEXT TO BE DELETED~~ (highlight text, under Format, click font and check strikethrough)
UNDERLINE TEXT TO BE ADDED
Use additional sheets of the form, if necessary.

See next page

Anticipated impact of code change on cost of construction (CHECK ONE)
 Increase *Decrease* *Negligible* *Unknown*

Per 1,000 SF single-family dwelling *to*
Per 1,000SF of commercial building *to*

JUSTIFICATION OF CHANGE:
Please reference one or more of the criteria required
 To address a critical life/safety, health, general welfare need.
 To address a specific District of Columbia policy or statute
 For consistency with federal, or with reference to the Metro DC area (MD, VA) codes
 Address a unique character issue in the District of Columbia
 Correction of errors and omissions
 Other (explain)

To specify a dyeing color for the gray water systems rather than leaving the requirement ambiguous.

Purple is consistent with current practice and matches the piping marking color required by Section 608.8.2 of IPC for non-potable water systems.

**SECTION 1302
SYSTEMS FOR FLUSHING WATER CLOSETS AND URINALS**

Strike Section 1302.4 of the International Plumbing Code in its entirety and insert new Sections 1302.4 to the Plumbing Code in its place to read as follows:

1302.4 Coloring. The *gray water* shall be dyed ~~blue or green~~ purple with a food grade vegetable dye before such water is supplied to the fixtures.